

TABLE OF DETECTED CONTAMINANTS 2025 - Village of Windsor

Contaminant	Violation Yes/No	Sample Location	Date of Sample	Level Detected (range)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
Barium	No	Well #1 Well #2	9/29/2023	0.025 0.0278	mg/l	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Lead ¹	No	Distribution	6/24-26/ 2025 12/16-17/ 2025	(0-9.51) 3.5055 (0.666-7.9) 2.5374	ug/l	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits.
Copper ¹	Yes	Distribution	6/24-26/ 2025 12/16-17/ 2025	(0.0687-1.25) .221515 (0.0506-1.59) 0.30191	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Nitrate (as Nitrogen)	No	Well #1 Well #2	9/30/2025	3.54 4.53	mg/l	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Sodium ²	No	Well #1 Well #2	9/30/2025	119 111	mg/l	N/A	See Health Effects	Naturally occurring; Road salt; Water softeners; Animal waste.
Disinfection Byproducts								
Total Trihalomethanes ³	No	Distribution	9/30/2025	.000960	ug/l	N/A	80	Byproduct of drinking water chlorination.
Haloacetic Acids ⁴	No	Distribution	9/24/2024	1.15	ug/l	N/A	60	Byproduct of drinking water chlorination.
Unregulated Perfluoroalkyl Substances And Synthetic Organic Compounds								
PFHxA	No	Well #1 Well #2	11/25/2025	1.76 1.78	ng/l	N/A	N/A	There are no regulations establishing an MCL for these compounds currently. Released into the environment through widespread use in commercial and industrial applications.
1,4 Dioxane	No	Well #2	11/25/2025	0.0576	ug/l	N/A	1	Released into the environment from commercial & industrial sources & is associated with inactive & hazardous waste sites.
PFPeA	No	Well #1 Well #2	11/25/2025	2.23 2.15	ng/l	N/A	N/A	There are no regulations establishing an MCL for these compounds currently. Released into the environment through widespread use in commercial and industrial applications.

Radiological Contaminants								
Gross Alpha	No	Well #1 Well #2	9/30/2025	0.7837 1.650	pCi/L	0	15	Erosion of natural deposits.
Radium-226	No	Well #1 Well #2	9/30/2025	0.0817 0.0857	pCi/L	0	5	Erosion of natural deposits.
Radium-228	No	Well #1 Well #2	9/30/2025	0.129 0.222	pCi/L	0	5	Erosion of natural deposits.
Notes:								
1	The level presented represents the 90th percentile of the sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead/copper values detected at your water system.							
2	Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.							
3	This level represents the total levels of the following contaminants: chloroform, bromodichloromethane, dibromochloromethane, bromoform.							
4	This level represents the total levels of the following contaminants: monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, monobromoacetic acid and dibromoacetic acid.							
Definitions:								
<u>Maximum Contaminant Level (MCL)</u> : The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.								
<u>Maximum Contaminant Level Goal (MCLG)</u> : The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.								
<u>Action Level (AL)</u> : The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.								
<u>Non-Detects (ND)</u> : Laboratory analysis indicates that the constituent is not present.								
<u>Milligrams per liter (mg/l)</u> : Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).								
<u>Micrograms per liter (ug/l)</u> : Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).								
<u>Nanograms per liter (ng/l)</u> : Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).								
Picocuries per liter (pCi/L): A measure of the radioactivity in water								