

TABLE OF DETECTED CONTAMINANTS 2021 - Village of Windsor

Contaminant	Violation Yes/No	Sample Location	Date of Sample	Level Detected (range)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
Barium	No	Well #1 Well #2	9/29/2020	0.0271 0.0269	mg/l	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Lead ¹	No	Distribution	9/28-30/2020	5.6 (1.5-6.7)	ug/l	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits.
Copper ¹	No	Distribution	9/28-30/2020	1.41 (0.0804-3.68)	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Nitrate (as Nitrogen)	No	Well #1 Well #2	9/30/2021	2.97 4.51	mg/l	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Sodium ²	No	Well #1 Well #2	9/30/2021	112 103	mg/l	N/A	See Health Effects	Naturally occurring; Road salt; Water softeners; Animal waste.
Disinfection Byproducts								
Total Trihalomethanes ³	No	Distribution	9/30/2021	3.19	ug/l	N/A	80	Byproduct of drinking water chlorination.
Haloacetic Acids ⁴	No	Distribution	9/30/2021	1.37	ug/l	N/A	60	Byproduct of drinking water chlorination.
Radiological Contaminants								
Gross Alpha	No	Well #1 Well #2	12/21/2016	ND 0.676	pCi/L	0	15	Erosion of natural deposits.
Radium-226	No	Well #1 Well #2	12/21/2016	0.0663 0.137	pCi/L	0	5	Erosion of natural deposits.
Radium-228	No	Well #1 Well #2	12/21/2016	0.501 0.216	pCi/L	0	5	Erosion of natural deposits.
Notes:								
1	The level presented represents the 90th percentile of the sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead/copper values detected at your water system.							
2	Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.							
3	This level represents the total levels of the following contaminants: chloroform, bromodichloromethane, dibromochloromethane, bromoform.							
4	This level represents the total levels of the following contaminants: monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, monobromoacetic acid and dibromoacetic acid.							
Definitions:								
<u>Maximum Contaminant Level (MCL):</u> The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.								
<u>Maximum Contaminant Level Goal (MCLG):</u> The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.								
<u>Action Level (AL):</u> The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.								
<u>Non-Detects (ND):</u> Laboratory analysis indicates that the constituent is not present.								
<u>Milligrams per liter (mg/l):</u> Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).								
<u>Micrograms per liter (ug/l):</u> Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).								
<u>Picocuries per liter (pCi/L):</u> A measure of the radioactivity in water.								